



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

D'ARCY DIXON PIGNANELLI
Executive Director

Division of Facilities Construction and Management

F. KEITH STEPAN
Director

ADDENDUM

Date: 12 October 2005

To: Contractors

From: Bill Bowen, Program Director, DFCM

Reference: Provo Regional Center HVAC & Controls Upgrade
DFCM Project No. 05031310

Subject: **Addendum No. 2**

Pages	Addendum	1 page
	Attachment (WHW Addendum)	1 pages
	<u>Drawings</u>	<u>0 pages</u>
	Total	2 pages

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

1. Reference attached addendum from WHW Engineers, Inc.

ADDENDUM

Project Name: Provo Regional Center HVAC Upgrade

Addendum No.: 2

DFCM Project #: 05031310

Date: 10-11-05

From: WHW Engineering Inc
1354 East 3300 South Suite 200
Salt Lake City, Utah 84106
Phone (801) 466-4021 Fax (801) 466-8536

To: All bidders

This Addendum forms and becomes a part of the Contract Documents and modifies the original Bidding Documents dated September 2005 as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 1 pages.

I - CHANGES TO PRIOR ADDENDA: NA

II - CHANGES TO BIDDING REQUIREMENTS: NA

III - CHANGES TO AGREEMENT & OTHER CONTRACT FORMS: NA

IV – CHANGES/CLARIFICATIONS TO CONDITIONS OF THE CONTRACT: NA

V - CHANGES/CLARIFICATIONS TO SPECIFICATIONS:

Item V-1: Specification section 15671 – 2.1. insert the following paragraph:

- “K. Approved manufacturers and models:
1. Carrier 38AH
 2. Trane RAU or equal by
 3. York
 4. TSI”

Item V-2: Specification section 15761 – 2.1.B. add the following approved manufacturers:

- “
5. York
 6. RAE Corp Coils”

VI - CHANGES/CLARIFICATIONS TO DRAWINGS:

Item VI-1: Sheet ME501 detail C3 clarification:

Existing roof is a HPG roof that is now owned by Johns Manville. Any JM approved applicator that will honor the remainder of the roof warranty is approved to do any roof patching as required by this project.